

School of Civil Engineering and Geoscience Environmental Engineering

# CEG8108 Environmental Engineering Design and Project Management

Detailed design proposal for a wastewater treatment plant in Newtown Aycliffe.

Module leader: Dr. Paul Sallis

Giacomo Butte' 180529115 March 2019

## Contents

Executive summary

2

7

- 1. Assumptions 4
- 2. Primary treatment
- 3. Secondary treatment 11
- 4. Tertiary treatment 17
- 5. Sludge management 18
- 6. Operational carbon footprint. 20
- 7. Operational costing 22
- 8. References 24

## **List of tables**

Table 0: summary of water quality, flow and by products for treatment system 3 Table 1: discharge flows 4 Table 2: water characteristics and targets 4 5 Table 3: technnology comparison for water treatment 5 Table 4: technnology comparison for sludge treatment Table 5: primary treatment summary table 7 Table 6: grit unit summary table 7 Table 7: sedimentation tank summary 7 Table 8: calculation of equalization basin volume10 Table 9: summary table for aerobic tank 11 Table 10: summary table for anoxic design 11 Table 11: summary table for phosphorus removal 11 Table 12: comparison between different phosphorus removal systems. 11 Table 13: summary table for UV disinfection 17 Table 14: summary of disposal for treatment byproducts 19 Table 15: energy intensity for different WWTP 20 Table 16: direct and indirect emissions for the wastewater plant 21 Table 17: measures to reduce energy consumption 21

## **List of figures**

7

- Figure 0: treatment system diagram
- Figure 1: consumption forecast 2019-2038 4
- Figure 2: daily water discharge pattern
- Figure 3: cumulative volume curve 7
- Figure 4: schematic diagram of the pretreatment phase.
- Figure 5: schematic diagram of secondary treatment. 11
- Figure 6: system mass balance for sludge 18
- Figure 7: operational cost breakdown

## Figure 8: comparison of operational costs between Newtown WWTP and 22 WWTPs in Spain. 22

3

4

22

## **Executive summary**

CASSIE Environmental Consulting was hired to design a wastewater treatment plant for the municipality of Newtown Aycliffe in England. A conceptual proposal was submitted prior to this report to receive feedback from the involved stakeholders. This report represents the second and final step in the consultancy part of the project.

The municipality has a current population of 26,000 people with a growth of around 1% per year. The wastewater treatment plant will receive only domestic discharges estimated at around 3200 m<sup>3</sup>/day. In the next two decades daily discharge are expected to reduce due to DEFRA target of 130L/p.e. day discharge.

The wastewater characteristics were estimated via sampling and laboratory analysis. BOD, suspended solids, total nitrogen and phosphorus concentration were estimated at 305 mg/L,236 mg/L, 40 mg/L, 14 mg/L respectively. Effluent target requirements include BOD < 25 mg/L, total suspended solids < 150 mg/L, total nitrogen < 15 mg/L and phosphorus < 2 mg/L.

A summary of water characteristics after each process unit is shown in table 0.

The proposed system for biological treatment is an Anaerobic / Anoxic / Oxic (AAO) process that allows for standard treatment and nutrient removal. Nitrogen concentration is lowered within target levels. Phosphorus removal is completed by chemical precipitation. Effluent water is disinfected by UV light. The final effluent for the treatment plant are expected to be within requirements: BOD 18mg/L, TSS 25 mg/L, TKN < 0.5 mg/L, P <2 mg/L and coliforms 1.2 10<sup>-5</sup>MPN/100 ml.

Sludge is treated by alkaline addition with the possibility of agricultural reuse. Sludge production from primary and secondary treatment is estimated at 257 kg/ day. Sludge from phosphorus precipitation by alum is estimated at 400 L/day. An overview of the treatment process is given in Figure 0.

An evaluation of possible sources of green house gases was conducted. The plant will emit directly N2O and CH4 during the different steps of the process. Indirect emissions will come mainly from electrical energy used, transport and chemical used. The carbon footprint estimated emissions were not calculated but reference values were gathered.

Operational costs were determined using a cost function and estimates found in literature. The expenditure reaches 230,000 £/year. The breakdown of the costs was estimated as follows: staff 37%, energy 20%, maintenance 16%, chemical reagents 15% waste disposal 12%.



#### ingure of theutinent system utugram

Unit	Description	Flow	Leght	BODe	TSS	TKN	Р	Byproducts	coliforms <sup>a</sup>
		m³/h	h	mg/L	mg/L	mg/l	mg/L	per day	MPN/100 ml
	wastewater	11-309		305	236	40	14.6		1.2 10 <sup>7</sup>
U01	coarse screening	11-309		274	200			155 L	1.14 10 <sup>7</sup>
U01	fine screening	11-309		274	200			233 L	9.6 10 <sup>6</sup>
U02	grit chamber	129						67 L	7.7 10 <sup>6</sup>
U03	flow equalizer	129	0-2						
U04	primary clarifier	129	2	183	90			341 kg	3.8 10 <sup>6</sup>
U05A	anaerobic tank	129	1				6.8		
U05B	anoxic tank	129	1.7			0.5 <sup>b</sup>		323 kg	1.55 10⁵
U05C	oxic tank	129	12	56	46				
U06	secondary clarifier	129	2	18	25			64 kg	7.7 10 <sup>4</sup>
U07	Phosphorus chemi- cal removal	129		18	25		2	400 L	
U13	disinfection	129		18	25	0.5 <sup>b</sup>	2		1.2 10-5

a : estimate based on literature (Metcalf 2003: Table 12-2)

b: as NH4-N

## 1. Assumptions

Compared to the conceptual proposal, additional estimates and assumptions were made. Below a brief summary of the changes.

**Demographic estimates.** This study uses a 20-year timeframe. This is a typical return on investment period. An estimated population for 2038 is 27,310. This number is obtained by linearly projecting the growth rate in the period 2001 to 2011. The result is a 10-year growth of nearly 1%. Considering the estimated growth for the whole Durham County (ONS 2018) in the period 2016-2026 is 3%, this seems a reasonable value. (Calculation 1.1)

Sewerage system assumption. Assuming the recent construction of the township, a separate sewerage system is assumed. Direct storm water contribution is not considered. Infiltration through system leakages could be estimated at 0.5 m3/ ha\*day (Metcalf & Eddy 2003). Considering Newtown Aycliffe urban area (approximately 526 hectares) the entity of this contribution is not significant (8%) and was not taken into account. (Calculation 1.3)

**Water quantity.** A discharge estimate for the coming two decades was calculated. For 2011 the current daily consumption of 150L/person was assumed, while for 2038 ,aligned with DEFRA targets, a consumption of 130L/person was assumed. A visualization of the trend is shown in Figure 1. Despite population growth, wastewater discharge should decrease in the coming years. For this study the discharge from 2011 was used. Additionally, it is assumed that the wastewater plant will serve only the residential part of the town (Calculations 1.2).

An hypotetical daily flow discharge pattern was assumed with a peak flow factor of 2.5 (Figure 2). An equalization basin was added to the process. This will provide a stable flow through the day and decrease loading shocks. The additional costs for its construction will be reduced by size savings obtained by avoiding peak flow as the design benchmark.

**Water quality.** A few additional assumptions were necessary for nutrient removal calculations. Total nitrogen was estimated at 40 mg/L. Estimates based on literature of COD (610 mg/L), bCOD (500 mg/L) and rbCOD (170 mg/L) were necessary for the calculation of Phosphorus removal. A summary of water characteristics is shown in Table 2.

#### Table 1: discharge flows

Parameter	Value
Daily average flow	3,107
Hourly average flow	129
Hourly peak flow	323







#### Figure 2: daily water discharge pattern

The figure shows an hypotetical inflow pattern (Inflow) used to calculate the equalization basin (Figure 3).

#### Table 2: water characteristics and targets

Variable	Influent	Target	Comment
BOD (mg/L)	305	25b	
COD (mg/L)	610		Estimated as BOD x 2
bCOD	500		Assumed as 1.64 of BOD <sup>c</sup>
rbCOD	170		Assumed as 0.3 of bCOD
Total Suspended Solids (mg/L)	236	150 b	
Volatile Suspended Solids	189		Assumed as x0.8 of TSS
рН	7.05		
NH4+ (mg N/L)	26.2		
Total nitrogen (mg/L)	40	15 b	Assumed <sup>a</sup>
NO3_N	7		
NOx	25		Assumed
Total P (mg P/L)	14.4	2 b	
Faecal coliforms (MPN / 100 mL)	1.2 x 10 <sup>7</sup>	<1000	
Helminths (eggs/L)	Nd	<1	

a: (Metcalf & Eddy 2003:213)

b: The Urban Waste Water Treatment (England and Wales) Regulations 1994 c: (Metcalf & Eddy 2003:670)

c: (Metcall & Eddy 2003.670)

**Technology proposed.** Different technologies were re-evaluated using five criteria. Two related to the efficacy of the treatment: the ability to reach standard effluent quality and the possibility of incorporating nutrient removal units. A third parameter is related to the possibility and ease of numerical modelling. The increasing need for energy efficient technologies and the area footprint were the last two parameters considered. A summary of the evaluation is shown in Table 3. Some technologies were not considered for poor energy afficiency (MBR, SBR, MBBR). Trickling filter would need additional units in the process to ensure proper nutrient removal. These additions would neutralize its advantages. Aerobic Granular Sludge in recent years proved to be an effective and interesting technology but its modelling, based on biofilm biochemistry, could not be done precisely without the involvement of an industry partner.

The technology proposed is still activated sludge but in the form of Anaerobic-Anoxic-Oxic (A/A/O) system. This setting seems to give the best performance in the parameters evaluated. A qualitative assessment of different technologies is shown in Table 3.

**Disinfection**. The process proposed remained UV light. This technology was considered because of its efficacy, lack of residuals in the discharge and suitability to work with low volume of water.

**Sludge management.** The proposed treatment changed from the initial report. Different treatments were assessed based on five parameters (Table 4): suitability to low sludge volume (C1), proximity of residential area (C2), possibility of sludge reuse (C3), energy efficiency (C4), efficiency of treatment versus costs (C5). The proposed system includes centrifuges for thiskening and dewatering and chemical treatment using lime.

Since the sludge is expected to be reused for agricultural purposes, discharge from alum precipitation in the final stage of phosphorus removal is kept separated from the rest.

#### Table 3: technnology comparison for water treatment

	_					
	MBR	SBR	AGST	MBBR	ΤF	AAO
Effluent	3	3	3	3	3	3
Nutrient removal	3	2	3	3	1	3
Numerical modelling	2	3	2	2	3	3
Energy efficiency	1	1	2	1	3	2
Area	3	3	3	3	2	3
	12	12	13	12	12	14

Rating system: 3 : very favourable 2: favourable

1: not very favourable

MBR	membrane bio reactor
SBR	sequence batch reactor
AGST	aerobic granular sludge
MBBR	moving beds bio reactor
TF	trickling filter
AAO	aerobic, anoxic, oxic

#### Table 4: technnology comparison for sludge treatment

	C1	C2	C3	C4	C5
Thickenir	ng an	d dew	aterir	ng	
Sedimentation	2	2	2	3	2
Centrifuges	3	3	3	2	3
DAF	2	2	2	1	2
Belt	2	2	3	2	3
Thermal	2	2	3	1	2
Slud	lge tre	eatme	ent		
Composting	1	1	3	2	2
Anaerobic	1	2	2	3	2
Chemical	3	3	2	2	2

Rating system:

3 : very favourable

2: favourable

1: not very favourable

Criteria:

C1: suitability to low sludge volume C2: proximity of residential area C3: possibility of sludge reuse C4: energy efficiency C5: efficiency of treatment versus costs (CAPEX+OPEX)

## Assumptions: calculations.

**<u>1.1 Population projection</u>**. An estimated population for 2038 is calculated projecting the growth rate for the period 2001 to 2011.

$$P_{2001} \coloneqq 26385 \quad P_{2011} \coloneqq 26633 \qquad P_{2019} \coloneqq 26758$$
$$dP_{10yrs} \coloneqq 1 + \frac{P_{2011} - P_{2001}}{P_{2001}} = 1.009 \quad dP_{yr} \coloneqq \left(dP_{10yrs}\right)^{0.1} = 1.001 \qquad P_{2038} \coloneqq P_{2011} \cdot dP_{yr}^{27} = 2.731 \times 10^{4}$$

**1.2 Discharge from population:** population in 2038 is assumed 27,310. A daily consumption 150 L/day\*person is assumed but DEFRA plan is to reduce water consumption to 130L/person by 2030. A return factor of 80% is used. Peak factor estimated at 2.5

$$Q_{p_{day}} := 150 \frac{L}{day}$$
  $f_r := 0.8$   $f_p := 2.5$ 

Discharge flow are estimated for the next 20 years considering population change and reduced water consumption. Yearly consumption decrease is estimated at 0.66L/p.e every year considering reduction from 150L/p.e.\*day to 130 in 30 years time.

$$\mathsf{Z}(\mathsf{t}) \coloneqq \mathsf{P}_{2011} \cdot \left(\mathsf{dP}_{\mathsf{yr}}\right)^{\mathsf{t}} \cdot \mathsf{f}_{\mathsf{r}} \cdot (150 - 0.66 \cdot \mathsf{t})$$

Discharge 2019 $Z(8) = 3.107 \times 10^6$ Discharge 2029 $Z(18) = 2.993 \times 10^6$ Discharge 2038 $Z(28) = 2.877 \times 10^6$ 

Considering the decreasing trend, 2019 is used as a benchmark for the calculations.

$$Q_{day\_avg} \coloneqq Z(8) \cdot \frac{L}{day} = 3.107 \times 10^3 \cdot \frac{m^3}{day} \qquad \qquad Q_{h\_peak} \coloneqq Q_{day\_avg} \cdot f_p = 323.607 \cdot \frac{m^3}{hr}$$

**<u>1.3 Infiltration from precipitation</u>**: An infiltration rate via system leakages of 0.5 m3/ha\*day is used. This value is taken from the range given by Metcalf of 0.2-28 m3/ha\*day. Infiltration is estimated as 8% of inflow and therefore not considered.

## 2. Primary treatment



Figure 4: schematic diagram of the pretreatment phase.

### Unit 1: screening (Calculation 2.1 and 2.2)

The screening cell consists of a trash rack with 80mm spaced with semi-circular sections (upstream face) and a mechanical cleaned fine screen with 13mm spacing. Both screens are inclined at 60 degrees. Even if the screening quantity is very variable depending on location, climate, topography a general estimate can be done using the following rate of grit per volume of influent: 0.004 L/m^3 (ASCE 1998:9–13). A summary of quantities and characteristics of removal is shown in Table 5: coarse screening and grit composition and estimated removed quantity. The disposal of the coarse screening should be done by delivering it to the nearest disposal site.

### Unit 2: grit removal

The second unit consist of a vortex grit removal system. This solution is preferred to others for its efficiency both in term of performance (up to 90% removal) and energy. It can work on a wide flow variation and produces minimal head loss and space requirement. After removal the grit should be washed. A first estimate of measurements based on literature (Metcalf, 2003) is shown in Table 6. Grit should be disposed to handling facilities.

### Odour control for screening and grit.

The pre-treatment phase may produce obnoxious odours. This is caused by emission of different gases such as hydrogen sulphide, indoles, skatoles, amines, ammonia, carbon dioxide and methane (Water Environmental Federation 1995). Some of the key variables are sludge sulphur composition, management and loading and therefore hard to predict on theoretical basis. In case this problem will arise, the management company may use one of the many available remediation which include addition of chlorine or peroxide, pH adjustment, pre-areation or air scrubbing.

### Unit 3: flow equalizer (Table 8).

Considering that the peak flow factor for this community is quite high (estimated in the concept reportat 2.5), an equalization tank might be necessary. A tank of 1000 m<sup>3</sup> would fully equalize the flow at 129 m<sup>3</sup>/h. This option seemed more favourable than a 790 m<sup>3</sup> option that would contain the peak flow only within 1.5. Full calculations shown in Talbe 8.

### Unit 4: sedimentation tank (Calculation 2.3).

Two rectangular sedimentation tanks are proposed. Given the physical and chemical composition of the sludge, the general law of sedimentation is not applicable. Overflow rate used for the design is  $30 \text{ m}3/\text{m}2^{*}$ d. This value is just below the optimal range of of  $32-48\text{m}3/\text{m}2^{*}$ d (Metcalf & Eddy 2003) but resulting in an ideal 2h retention time.

The size of each sedimentation tank is 5m x 10m with a depth of 2.5m. The average retention time is 2 hours. Horizontal velocity is below organic and grit scour velocity therefore it should not create re-suspention. An estimation of BOD and SS removal was estimated giving values 33% and 54% respectively. A summary of the sedimentation unit is shown in Table 7.

#### Table 5: primary treatment summary

Coarse screening				
width	0.55m			
bar section	semicircular 10x30mm			
spacing	80mm			
head loss	0.5 m			
screening	155 L/day			
Inclination	60 degrees			
Fine s	creening			
screening size	13mm			
removal type	mechanical			
head loss	0.017m			
screening	232 L/day			

### Table 6: grit unit summary

diameter upper chamber	4m
diameter lower chamber	1.2m
height	3m
mesh size	0.30 mm
removal rate	95%
grit removed	0.06 m <sup>3</sup> / day

### Table 7: sedimentation tank summary

size (w,L,d)	5x10x2.5m
number of tanks	2
BOD removal	33%
TSS removal	54%



**Figure 3: cumulative volume curve** The graph shows the inflow (cumulative inflow) the equalized discharge \*Cumulative outflow) at an average of 129 m3/h and the volume of water stored in the tank at every hour (Storage quantity). The storage volume is estimated at 1000 m<sup>3</sup>. Calculations shown in table 8

2.1 Pretreatment (PT) velocity considerations. Ideal flow velocity passing through a screen should be in the range of 0.4-0.9 m/s with a possible peak flow design around 0.76 m/s (ASCE 1998).  $vel_{PT_min} = 0.4 \frac{m}{s}$  $vel_{PT_peak} := 0.76 \frac{m}{s}$   $vel_{PT_max} := 0.9 \frac{m}{s}$  $A_{PT\_min} \coloneqq \frac{Q_{day\_avg}}{vel_{PT\_min}} = 0.09 \, \text{m}^2 \qquad A_{PT\_peak} \coloneqq \frac{Q_{h\_peak}}{vel_{PT\_peak}} = 0.118 \, \text{m}^2$ Considering a width of 0.48m the depth variation is of few centimeters only  $w_{PT} := 0.48m h_{PT\_min} := \frac{A_{PT\_min}}{w_{PT}} = 0.187m h_{PT\_max} := \frac{A_{PT\_peak}}{w_{PT}} = 0.246m$ Pretreatment screening design. Coarse screening, the screening phase consists of a trash rack with 80mm spaced, semicircular sections (upstream face), bar shape factor at 1.83 (B.PT). Both screen inclined at 60 dearees.  $n_{PT} := \frac{w_{PT}}{0.08m} + 1 = 7$   $\theta_{PT} := 60 \text{deg } B_{PT} := 1.83 \frac{s^2}{m}$ Trash rack head bss calculation. Number of bars <sup>w</sup>PT chamber := <sup>w</sup>PT + <sup>n</sup>PT  $\cdot$  0.01m = 0.55m  $w_b_{PT ratio} := 1$   $H_{PT} := \frac{vel_{PT_peak}^2}{2} \cdot w_b_{PT ratio} \cdot sin(\theta_{PT}) \cdot B_{PT} = 0.458 \text{ m}$ Screening volume calculated using 50L/1000m3 (Metcalf, 2003). Screen<sub>PT\_coarse</sub> :=  $Q_{day_avg} \cdot \frac{50L}{1000m^3} = 155.331 \cdot \frac{L}{day}$ 2.2 Pretreatment design. Fine screening. Mechanical cleaned fine screen with 13mm spacing, screening removal estimated at 75L/1000m3 (Metcalf. 2003). Screen<sub>PT\_fine</sub> :=  $\frac{75}{1000} \frac{L}{(m)^3} \cdot Q_{day_avg} = 232.997 \cdot \frac{L}{day}$  $C_{PT_fine} := 0.6$   $A_{PT_fine} := w_{PT_chamber} \cdot h_{PT_min}$   $h_{loss} := \frac{1}{2g} \cdot \left( \frac{Q_{day_avg}}{C_{PT_fine} \cdot A_{PT_fine}} \right)^2 = 0.017 \cdot m$ 2.3 Sedimentation tank (ST). Two rectangular tanks with a depth of 2.5m are proposed. Overflow rate range considered is 32-48 m3/m2\*d (Metcalf 1991). Within this flow rate removal of SS should be between 65%, BOD removal 45% (Metcalf 1991). Equalization tank will avoid peak flows.  $h_{ST} := 2.5m$   $A_{ST} := \frac{Q_{day\_avg}}{2 \cdot 30 - \frac{m^3}{2}} = 51.777 \text{ m}^2$ Dimension of each tank L=10m W=5m h=2.5m Sedimentation tank solid retention time (HRT.ST). A typical retention time is considered to be 2.0 hr (Metcalf 1991).  $\theta_{\text{ST}} := \frac{\left(A_{\text{ST}} \cdot h_{\text{ST}} \cdot 2\right)}{Q_{\text{down over}}} = 2 \cdot hr$ 

1.9 Sedimentation tank velocity considerations. To verify that settled material will not become resuspended, the horizontal velocity (vel.hor) should be slower than scour velocity. For scour velocity the following parameters are used:

constant for sticky material  $\beta_{ST} := 0.06$  organic matter density  $\rho_{org} := 1.2$ f<sub>ST</sub> := 0.03 Sand silt clay density Darcy Weisbach factor  $\rho_{s} \coloneqq 2.65$  $C_{D} := 10$  water density drag coefficient  $\rho := 1$ particle diameter D<sub>part ST</sub> := 0.02cm  $vel_{ST\_scour\_grit} \coloneqq \left\lceil \frac{8 \cdot \beta_{ST} \cdot \left(\rho_{s} - 1\right) g \cdot D_{part\_ST}}{f_{ST}} \right\rceil^{0.5} = 0.228 \frac{m}{s}$  $vel_{ST\_scour\_org} := \left[\frac{8 \cdot \beta_{ST} \cdot (\rho_{org} - 1)g \cdot D_{part\_ST}}{f_{ST}}\right]^{0.5} = 0.079 \frac{m}{s}$  $vel_{ST\_hor} := \frac{Q_{day\_avg}}{A_{ST}} = 6.944 \times 10^{-4} \frac{m}{s} \quad vel_{ST\_hor\_peak} := \frac{Q_{h\_peak}}{A_{ST}} = 1.736 \times 10^{-3} \frac{m}{s}$ 

Horizontal velocities during average and epak flow are slower than both organic and grit scour velocity, no resuspencion should accour.

1.10 Sedimentation tank BOD and TSS removal. Literature (Metcalf 1991) proposes an empirical formula for BOD and TSS removal at T=20C. Considering that the average temperature is 15.72C, the removal was calculated after adjusting the retention time with a multiplier (M).

Retention time equivalent to 20C:

$$T_{avg} := 15.72$$
  $M_{ST} := 1.82 \cdot e^{-0.03T_{avg}} = 1.136$   $\theta_{ST_T20_avg} := \frac{\theta_{ST}}{M_{ST}} = 1.761 \cdot hr$ 

BOD removal: <sup>a</sup>ST BOD := 0.018 · hr bST BOD := 0.02

$$BOD_{ST\_rem\_avg} \coloneqq \frac{\theta_{ST\_T20\_avg}}{\theta_{ST\_BOD} + \theta_{ST\_BOD} \cdot \theta_{ST\_T20\_avg}} \cdot \frac{1}{100} = 33.089 \cdot \%$$

BOD effluent from tank. 10% of BOD was removed in pretreatment

$$BOD_{PT\_rem} \coloneqq 0.92 \quad BOD_0 \coloneqq 305 \frac{mg}{L}$$
$$BOD_{ST\_eff} \coloneqq BOD_0 \cdot BOD_{PT\_rem} \cdot (1 - BOD_{ST\_rem\_avg}) = 187.751 \cdot \frac{mg}{L}$$

TSS removal: a<sub>ST\_TSS</sub> := 0.0075 · hr b<sub>ST\_TSS</sub> := 0.014

$$TSS_{ST\_rem} \coloneqq \frac{\theta_{ST\_T20\_avg}}{a_{ST\_TSS} + \theta_{ST\_TSS} \cdot \theta_{ST\_T20\_avg}} \cdot \frac{1}{100} = 54.768 \cdot \%$$

 $TSS_{PT rem} := 0.85 TSS_0 := 236 \frac{mg}{r}$ TSS effluent. 15% of TSS was removed in pretreatment.

$$TSS_{ST\_eff} := TSS_0 \cdot TSS_{PT\_rem} \cdot (1 - TSS_{ST\_rem}) = 90.735 \cdot \frac{mg}{L}$$

Estimated total suspended solids accumulated for each day:

 $TSS_{ST\_acc} := \left[ \left( TSS_0 \cdot TSS_{PT\_rem} \right) - TSS_{ST\_eff} \right] \cdot Q_{day\_avg} = 341.309 \cdot \frac{kg}{dav}$ 

Hourly flow variation was assumed based on a published example (Lin 2007).

hr	fhr	Out	storage	tank	balance	In sum	out sum
1	11.23	129.73	-118.50	554	-118.50	11.23	129.73
2	18.00	129.73	-111.73	442	-230.23	29.23	259.46
3	34.20	129.73	-95.53	347	-325.76	63.43	389.19
4	32.40	129.73	-97.33	249	-423.09	95.83	518.92
5	39.60	129.73	-90.13	159	-513.22	135.43	648.65
6	46.80	129.73	-82.93	76	-596.15	182.23	778.38
7	77.36	129.73	-52.37	24	-648.51	259.60	908.11
8	105.84	129.73	-23.89	0	-672.40	365.44	1037.84
9	213.12	129.73	83.39	83	-589.01	578.56	1167.57
10	255.60	129.73	125.87	209	-463.14	834.16	1297.3
11	292.32	129.73	162.59	372	-300.55	1126.48	1427.03
12	309.10	129.73	179.37	551	-121.18	1435.58	1556.76
13	277.92	129.73	148.19	699	27.01	1713.50	1686.49
14	220.32	129.73	90.59	790	117.60	1933.82	1816.22
15	183.60	129.73	53.87	844	171.47	2117.42	1945.95
16	176.40	129.73	46.67	891	218.14	2293.82	2075.68
17	169.20	129.73	39.47	930	257.61	2463.02	2205.41
18	144.00	129.73	14.27	944	271.88	2607.02	2335.14
19	140.76	129.73	11.03	955	282.91	2747.78	2464.87
20	111.60	129.73	-18.13	937	264.78	2859.38	2594.6
21	84.60	129.73	-45.13	892	219.65	2943.98	2724.33
22	75.94	129.73	-53.79	838	165.86	3019.92	2854.06
23	54.00	129.73	-75.73	763	90.13	3073.92	2983.79
24	39.60	129.73	-90.13	672	0.00	3113.52	3113.52

hr: day time F hr: hourly flow Out: equalized hourly flow hourly flow balance (f hr - Out) Storage: tank: volume of water in sedimentation tank balance: cumulative balance (balcen from previous hour + balance current hour) cumulative inflow In sum: cumulative outflow Out sum:

## 3. Secondary treatment



Figure 5: schematic diagram of secondary treatment.

Unit 5: Anaerobic, Anoxic Oxic unit. (Calculations 3.1 - 3.7)

The secondary treatment is aimed at nutrient and BOD removal. The Anaerobic, Anoxic, Oxic (AAO) was preferred to other nutrient removal technologies. The factors leading to this choice are: ability to reach the target nutrient removal, simplicity of construction and operation. Table 12 shows a comparison with other treatments. The AAO system, in this particular case of rich bCOD influent water, gives the most favourable solution.

### Table 12: comparison between different phosphorus removal systems.

Process	N removal	P removal	SRT	Complexity	Notes
Phoredox (A/O)	no	yes	2-4 d	low	
AAO	yes	yes	7-15 d	medium	
Bardenpho	yes	yes	10-20 d	high	
Virginia Initiative Plant	yes	yes	5-10 d	high	
Johannesburgh type	yes	yes	average	high	for weak water
PhoStrip	yes	yes	5-20	high	chemical precipitation

#### Table 9: summary table for aerobic tank

Average flow	3107 m³/d
Avg BOD load	570 kg/d
Avg TKN load	124 kg/d
Aerobic SRT	9.2 days
Aeration tanks	2
Tank volume	770+770 m <sup>3</sup>
Tank size (WxLxH)	11x17x4 (each)
HRT	12 h
MLSS	3000 g/m³
MLVSS	2310 g/m³
F/M	0.16
BOD loading	0.375 kg/m³*d
Sludge production	323 kg/d
Observed yield	0.80 gTSS/g BOD
	0.64 gVSS/gBOD
Air flowrate average	10 m³/min
RAS ratio	0.6
Clarifier application rate	22 m³/m²*day
Clarifier units	2
Clarifier diameter	4.8m each
Effluent BOD	57 mg/L
TSSe	37 mg/L
Effluent NH4-N	<0.5 mg/L

### Table 10: summary table for anoxic design

The system was designed as two parallel lines so in case of maintenance the	treat-
ment plant can still operate.	

**Phosphorus removal (Calculation 3.18-3.22).** The combination of the first two units (anaerobic-anoxic) provides phosphorus removal to a concentration of 6.8 mg/L. The sludge produced will contain 7% of phosphorus. Additional removal is performed after the second clarifier with the addition of liquid alum (400 L/day).

Anoxic unit (calculation 3.8-3.17). The second step of the process reduces the concentration of nitrogen. The system was designed for a 3000 MLSS concentration. This required a volume of 220 m<sup>3</sup> with a detention time of 1.7 hours. Alkalinity should be added to the system, estimated at 509 kg of NaHCO<sub>3</sub>. Estimated oxygen requirement is 10 m<sup>3</sup>/min. A power consumption of 88 kWh based on a 0.4 kW/m<sup>3</sup> consumption. Table 10 shows the main characteristics of this sub-unit.

**Oxic unit.** The final unit provides aerobic conditions for additional removal. Each tank has a volume of 770 m<sup>3</sup> with a BOD loading of 0.375 kg/m<sup>3</sup>\*day. Aeration needed was estimated at 10 m<sup>3</sup>/min. The effluent water will contain the following concentrations: BOD mg/L, TSS 37 mg/L, NH4-N < 0.5 mg/L and P 6.8 mg/L. A summary of all the characteristcs can be seen in Table 9.

**Secondary clarification.** Two clarifiers with diameter of 4.8m each are proposed. A total surface of 141 m<sup>2</sup> should keep loading rate around  $22m^3/m^{2*}$ day which belongs to the lower range of acceptable loading and therefore provide good clarification. The solid loading will reach 4.4 kg/m<sup>2\*</sup>hr. A BOD removal of 33% is estimated bringing BOD level at 18 mg/L. TSS removal is estimated at 54% bringing concentration at the effluet of the clarifier at 24 mg/L.

•	•
Effluent NO <sub>3</sub> _N	6 g/m³
Internal recycle ratio	2.2
RAS recycle ratio	0.6
Anoxic Volume	220 m <sup>3</sup>
MLSS	3000 g/m³
Overall SDNR	0.273 gNO3/gMLSS*d
Detention time	1.7 h
Mixing power	88 kW
Alkalinity required	509 kg/d as NaHCO <sub>3</sub>

## Table 11: summary table for phosphorus removal

Effluent P	6.9 g/m³
P in sludge	7 %
SRT	1 h
Tank volume	129 m³

## Secondary treatment calculations

<u>3 .Nitrification parameters.</u> Water and kinetic parameters. Parameters taken from Metcalf (Metcalf 1991 : Table8-11)

$$\begin{split} \mathsf{NH4}_{N_0} &= 26.2 \, \frac{\mathsf{mg}}{\mathsf{L}} & \mathsf{TSS}_0 &= 236 \, \frac{\mathsf{mg}}{\mathsf{L}} & \mathsf{BOD}_{\mathsf{ST}\_e} &= 187 \, \frac{\mathsf{mg}}{\mathsf{L}} \\ \mathsf{DO}_{\mathsf{min}} &:= 2 \, \frac{\mathsf{mg}}{\mathsf{L}} & \mathsf{VSS}_0 &:= \mathsf{TSS}_0 \cdot 0.8 = 188.8 \, \frac{\mathsf{mg}}{\mathsf{L}} \\ \mathsf{bCOD} &:= \mathsf{BOD}_{\mathsf{ST}\_e} \cdot 1.64 = -306.68 \, \frac{\mathsf{mg}}{\mathsf{L}} & \mathsf{ncCOD} &:= \mathsf{bCOD} \cdot 0.3 = 92.004 \, \frac{\mathsf{mg}}{\mathsf{L}} & \mathsf{This ratio is assumed based} \\ \mathsf{bCOD} &:= 23 \, \frac{\mathsf{mg}}{\mathsf{L}} & \mathsf{calculation} al 2.3 & \mathsf{nbVSS} &:= 20 \, \frac{\mathsf{mg}}{\mathsf{L}} & \mathsf{BOD}_{\mathsf{load}} := \mathsf{O}_{\mathsf{day}\_avg} \, \mathsf{BOD}_{\mathsf{ST}\_eff} = 583.273 \, \frac{\mathsf{kg}}{\mathsf{day}} \\ \mathsf{Kinetic parameters:} \\ \mathsf{Wn\_m\_T16} &:= 0.75 \, \frac{\mathsf{gm}}{\mathsf{gm}\cdot\mathsf{day}} \left( 1.07 \, ^{15-20} = 0.535 \, \frac{\mathsf{gm}}{\mathsf{gm}\cdot\mathsf{day}} & \mathsf{Y}_{\mathsf{n}} = 0.12 & \mathsf{Y} := 0.4 \\ \mathsf{k}_{\mathsf{n}\_\mathsf{T15}} &:= 0.74 \, \frac{\mathsf{gm}}{\mathsf{m}} \, 1.03^{15-20} = 0.572 \, \frac{\mathsf{gm}}{\mathsf{m}} & \mathsf{k}_{\mathsf{o}} := 0.5 \, \frac{\mathsf{gm}}{\mathsf{m}^3} & \mathsf{K}_{\mathsf{o}} := 20 \, \frac{\mathsf{gm}}{\mathsf{m}^3} \\ \mathsf{k}_{\mathsf{dn}\_\mathsf{T15}} &:= 0.08 \, \frac{\mathsf{gm}}{\mathsf{gm}\cdot\mathsf{day}} \cdot 1.04^{15-20} = 0.066 \, \frac{\mathsf{gm}}{\mathsf{gm}\cdot\mathsf{day}} \\ \mathsf{k}_{\mathsf{m}\_\mathsf{T15}} &:= 0.58 \, \frac{\mathsf{gm}}{\mathsf{m}^3} & \mathsf{K}_{\mathsf{o}} := 20 \, \frac{\mathsf{gm}}{\mathsf{m}^3} \\ \mathsf{k}_{\mathsf{dn}\_\mathsf{T15}} &:= 0.12 & \mathsf{V} := 0.4 \\ \mathsf{k}_{\mathsf{dn}\_\mathsf{T15} := 0.08 \, \frac{\mathsf{gm}}{\mathsf{gm}\cdot\mathsf{day}} \cdot 1.04^{15-20} = 0.066 \, \frac{\mathsf{gm}}{\mathsf{gm}\cdot\mathsf{day}} \\ \mathsf{k}_{\mathsf{m}\_\mathsf{n}\_\mathsf{T15}} &:= 0.08 \, \frac{\mathsf{gm}}{\mathsf{m}} \cdot \mathsf{los}^{-1.13} & \mathsf{SRT}_{\mathsf{design}} := \mathsf{FS}\cdot\mathsf{SRT}_{\mathsf{ntr}} = 9.712 \, \mathsf{day} \\ \mathsf{32} \, \mathsf{Biomass produced} \, \mathsf{Frstly} \, \mathsf{two kinete parameters get adjusted to 15C \\ \mathsf{kd}_{\mathsf{N}\_\mathsf{T15}} := 0.12 \, \frac{\mathsf{gm}}{\mathsf{gm}\cdot\mathsf{day}} \cdot 1.07^{15-20} = 4.278 \, \frac{\mathsf{gm}}{\mathsf{gm}\cdot\mathsf{day}} \\ \mathsf{m}_{\mathsf{m}\_\mathsf{T15}} := 6 \, \frac{\mathsf{gm}}{\mathsf{gm}\cdot\mathsf{day}} \cdot 1.07^{15-20} = 0.499 \, \frac{\mathsf{gm}}{\mathsf{gm}\cdot\mathsf{day}} \\ \mathsf{hm}_{\mathsf{m}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m}} = \frac{\mathsf{K}_{\mathsf{S}} (1 + \mathsf{kd}\_\mathsf{N}\_\mathsf{T15} \,\mathsf{SRT}_{\mathsf{design}}) \\ \mathsf{m}_{\mathsf{m}\_\mathsf{m}} \\ \mathsf{m}_{\mathsf{M}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m} \\ \mathsf{m}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m} \\ \mathsf{m}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m} \\ \mathsf{m}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m} \\ \mathsf{m}\_\mathsf{m}\_\mathsf{m} \\ \mathsf{m}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m} \\ \mathsf{m}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m} \\ \mathsf{m}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m} \\ \mathsf{m}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m} \\ \mathsf{m}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m}\_\mathsf{m} \\ \mathsf{m}\_\mathsf{m}\_\mathsf$$

**3.3 Amount of nitrogen oxidized to nitrate.** Total nitrogen is assumed 40mg/L and N in the effluent 0.5 mg/L  
TKN := 40 
$$\frac{mg}{L}$$
 N<sub>eff</sub> := 0.5  $\frac{gm}{m}$  NO<sub>X</sub> := TKN - N<sub>eff</sub> = 0.12  $\frac{P_X_{L}bio_{-tot}}{Q_{day_{-}avg}}$  = 26.817  $\frac{mg}{L}$   
**3.4 Concentration of VSS and TSS in aeration basin.**  
VSS<sub>aer</sub> := P<sub>X\_bio\_tot</sub> + Q<sub>day\_avg</sub> nbVSS = 390.466  $\frac{kg}{dav}$   
TSS<sub>aer</sub> :=  $\frac{P_{X_bet}}{0.85}$  +  $\frac{P_{X_coll}}{0.85}$  +  $\frac{P_{X_notf}}{0.85}$  +  $P_{X_nNSS}$  + Q<sub>day\_avg</sub> (TSS<sub>0</sub> - VSS<sub>0</sub>) = 474.966  $\frac{kg}{day}$   
MLVSS<sub>aer</sub> := VSS<sub>aer</sub> SRT<sub>design</sub> = 3.792 × 10<sup>3</sup> kg  
MLSS<sub>aer</sub> := TSS<sub>aer</sub> SRT<sub>design</sub> = 4.613 × 10<sup>3</sup> kg  
**3.5 Aeration tark volume.** Volume is calculated for a 3000gMLSS/m3  
concentration  
MLSS<sub>aer</sub> :=  $\frac{Oag}{m}$  V<sub>aer</sub> :=  $\frac{MLSS_{aer_conc}}{MLSS_{aer_conc}}$  = 1.538 × 10<sup>3</sup> m<sup>3</sup>  $\tau_{aer}$  :=  $\frac{V_{aer}}{Q_{day_avg}}$  = 11.879 ·hr  
VSS<sub>fraction</sub> :=  $\frac{MLVSS_{aer}}{MLSS_{aer}}$  = 0.822 MLVSS<sub>aer\_conc</sub> := MLSS<sub>aer\_conc</sub> VSS<sub>fraction</sub> = 2.466 × 10<sup>3</sup>  $\frac{gm}{m^3}$   
**3.6 FM ratio and BOD volumetric loading.**  
FM<sub>rate</sub> :=  $\frac{Q_{day_avg}BOD_{ST_eff}}{MLVSS_{aer_conc}Vaer}$  = 0.154  $\frac{kg}{kg \cdot day}$  Lorg :=  $\frac{Q_{day_avg}BOD_{ST_eff}}{V_{aer}}$  = 0.379  $\frac{kg}{m^3}$ .  
**3.6 FM ratio and BOD volumetric loading.**  
FM<sub>rate</sub> :=  $\frac{TSS_{aer}}{MLVSS_{aer_conc}Vaer}$  = 0.154  $\frac{kg}{kg \cdot day}$  Lorg :=  $\frac{TSS_{aer}}{V_{oar}}$  = 0.81.6 = 0.64  $\frac{gVSS}{gBOD}$   
**3.7 BOD** effluent assume sBODe =3gm/m'3 TSS<sub>ST\_eff</sub> = 90.735  $\frac{gm}{m^3}$  sBODe := 3 $\frac{gm}{m^3}$   
BOD<sub>aer\_e</sub> := sBODe + 0.7 0.85 TSS\_{ST\_eff} = 56.987  $\frac{gm}{m^3}$   
TSS<sub>aer\_e</sub> := BOD<sub>aer\_e</sub> · Y<sub>obs\_TSS</sub> = 45.603  $\frac{gm}{m^3}$  asd := 21 · Y<sub>obs\_TSS</sub> = 16.805  
**Anoxic tank**

$$X_{b} := \frac{Q_{day\_avg} \cdot SRT_{design}}{V_{aer}} \cdot \frac{Y \cdot BOD_{0}}{1 + k_{d\_N\_T15} \cdot SRT_{design}} = 1.223 \times 10^{3} \cdot \frac{gm}{m^{3}}$$

3.9 Internal recycle ratio. Ratio is calculated for a concentration in the effluent of 6gm/m3

NO3\_N<sub>RAS</sub> := 
$$6\frac{gm}{m^3}$$
 RAS ratio 0.6  $f_{RAS}$  := 0.6 IR :=  $\frac{NO_x}{NO3_N_{RAS}} - 1 - f_{RAS} = 2.87$ 

# 3.10 Amount of NO3\_N fed into the ano:

$$\frac{D}{NOX_N_{anox_in}} := IR \cdot Q_{day_avg} + f_{RAS} \cdot Q_{day_avg} = 1.078 \times 10^4 \cdot \frac{m^3}{day}$$
$$NOX_N_{feed} := NOX_N_{anox_in} \cdot NO3_N_{RAS} = 64.672 \cdot \frac{kg}{day}$$

3.11 Anoxic tank volume

$$\tau_{anox} := 1.7hr$$
  $V_{anox} := \tau_{anox} \cdot Q_{day_{avg}} = 220.053 \cdot m^3$ 

ka

F/M ratio

$$\mathsf{FM}_{rate\_N} := \frac{\mathsf{Q}_{day\_avg} \cdot \mathsf{BOD}_{ST\_eff}}{\mathsf{V}_{anox} \cdot \mathsf{X}_{b}} = 2.168 \cdot \frac{\mathsf{gm}}{\mathsf{gm} \cdot \mathsf{day}}$$

3.12 Determination of new SDNR. SDRN at 20C assumed at 0.31g/g\*d

$$\mathsf{SDNR}_{\mathsf{T15}} \coloneqq 0.31 \frac{\mathsf{gm}}{\mathsf{gm} \cdot \mathsf{day}} \cdot 1.026^{\left(15-20\right)} = 0.273 \cdot \frac{\mathsf{gm}}{\mathsf{gm} \cdot \mathsf{day}}$$

<u>3.13 Nitrogen that can be reduced.</u> The retention time in the anoxic tank has been optimized to match with the feed.

$$NO_{red} := SDNR_{T15} \cdot V_{anox} \cdot X_b = 73.36 \cdot \frac{kg}{day}$$
 Comparison with feed  $C_{nitr} := \frac{NO_{red}}{NOX_N_{feed}} = 1.134$ 

3.14 Comparison of SDNR value with reported range of 0.04-0.42 g/g\*d

$$SDNR_{MLSS} := 0.25 \cdot \frac{X_b}{MLSS_{aer\_conc}} = 0.102$$
 value is in range

3.15 Oxygen requirement.

$$O2_{req} \coloneqq Q_{day\_avg} \cdot (bCOD - S_{ntr\_e}) - 1.42P_{X\_bio\_tot} + 4.33Q_{day\_avg} \cdot NO_x = 35.174 \cdot \frac{kg}{hr}$$
$$O2_{credit} \coloneqq 2.86 \cdot (NO_x - N_{eff}) \cdot Q_{day\_avg} = 9.743 \cdot \frac{kg}{hr}$$
$$AOTR \coloneqq O2_{req} - O2_{credit} = 25.431 \cdot \frac{kg}{hr}$$

\_Oxygen concentration at 15C and 94m altitude, adjustment factor of 0.989

$$O2_{rel} \coloneqq O2_{T15\_h94} \cdot \frac{1}{2} \cdot \left( \frac{P_{atm} - P_{eff\_depth}}{P_{atm}} + \frac{O_{rel}}{21} \right) = 7.231 \cdot \frac{mg}{L}$$

$$SOTR \coloneqq AOTR \cdot \left[ \frac{O2_{std}}{\alpha_{air} \cdot F_{air} \cdot (\beta_{air} \cdot O2_{rel} - DO)} \right] \cdot 1.024^{15-20} \cdot \alpha_{air} \cdot F_{air} = 42.12 \cdot \frac{kg}{hr}$$

$$Air_{flow} \coloneqq \frac{SOTR}{0.35 \cdot \rho_{O2\_T15}} = 10.608 \cdot \frac{m^3}{min}$$

3.16 Alka linity: ApH around 7 should be maintained. Influent pH is 7.05

Alk.i is netral (pH7.05) 
$$Alk_{used} \coloneqq 7.14 \cdot NO_x = 191.476 \cdot \frac{gm}{m^3}$$
  $Alk_{prod} \coloneqq 3.57 \cdot \left(NO_x - N_{eff}\right) = 93.953 \cdot \frac{gm}{m^3}$   
 $Alk_{tot} \coloneqq Alk_{prod} - Alk_{used} = -97.523 \cdot \frac{gm}{m^3}$   
 $Alk_{bal} \coloneqq Q_{day\_avg} \cdot Alk_{tot} = -302.968 \cdot \frac{kg}{day}$  CaCO3 or as NaHCO3 NaHCO3 := Alk\_{bal} \cdot \frac{84}{50} = -508.986 \cdot \frac{kg}{day}

3.17 Power consumption . Assuming 0.4kW/m3

$$Pw_{anox} := V_{anox} \cdot 0.4 \frac{kW}{m^3} = 88.021 \cdot kW$$

## **Phosphorus removal**

**<u>3.18 rbCOD available for the biological phoshorus removal.</u> rbCOD from sedimentation tank is 90 gm/m3, rbCOD from recycle is** 

$$\begin{aligned} & \text{bCOD}_{\text{RAS}} \coloneqq \text{BOD}_{\text{aer_e}} : 1.64 = 93.459 - \frac{\text{mg}}{\text{L}} \quad \text{bCOD}_{\text{RAS}} := \text{bCOD}_{\text{RAS}} : 0.3 = 28.038 - \frac{\text{mg}}{\text{L}} \quad \text{rbCOD} = 0.092 - \frac{\text{kg}}{\text{m}^3} \\ & \text{rbCOD}_{\text{anae}} \coloneqq \frac{\text{Oday\_avg} : \text{rbCOD} + \text{Oday\_avg} : \text{fRAS} : \text{rbCOD}_{\text{RAS}} = 68.017 \cdot \frac{\text{gm}}{\text{m}^3} \\ & \text{NO3\_N_0} \coloneqq 0 - \frac{\text{mg}}{\text{L}} \quad \text{NO3\_N_{\text{RAS}}} = 6 - \frac{\text{gm}}{\text{m}^3} \\ & \text{NO3\_N_{\text{react}}} \coloneqq \frac{\text{Oday\_avg} : \text{NO3\_N_{\text{RAS}}} = 6 - \frac{\text{gm}}{\text{m}^3} \\ & \text{NO3\_N_{\text{react}}} \coloneqq \frac{\text{Oday\_avg} : \text{NO3\_N_{\text{RAS}}} = 6 - \frac{\text{gm}}{\text{m}^3} \\ & \text{NO3\_N_{\text{react}}} \coloneqq \frac{\text{Oday\_avg} : \text{NO3\_N_{\text{RAS}}} = 6 - \frac{\text{gm}}{\text{m}^3} \\ & \text{NO3\_N_{\text{react}}} \coloneqq \frac{\text{Oday\_avg} : \text{NO3\_N_{\text{RAS}}} = 6 - \frac{\text{gm}}{\text{m}^3} \\ & \text{rbCOD}_{\text{eq}} \coloneqq \text{NO3\_N_{\text{react}}} = 6.577 \cdot \frac{\text{gm}}{\text{m}^3} \\ & \text{rbCOD}_{\text{avlb}} \coloneqq \text{rbCOD}_{\text{avlb}} \coloneqq \text{rbCOD}_{\text{anae}} = - \text{NO3\_N_{\text{react}}} = 65.767 \cdot \frac{\text{gm}}{\text{m}^3} \\ & \text{Prem} \coloneqq \frac{\text{rbCOD}_{\text{avlb}}}{10} = 6.577 \cdot \frac{\text{gm}}{\text{m}^3} \\ & \text{Prem} \coloneqq \frac{\text{rbCOD}_{\text{avlb}}}{10} = 6.577 \cdot \frac{\text{gm}}{\text{m}^3} \\ & \text{Y} \simeq 0.4 \quad \text{kd} \coloneqq \frac{0.12}{\text{day}} \quad \text{kd}_{\text{n}} \coloneqq \frac{0.08}{\text{day}} \quad \text{NO}_{\text{x}} = 26.817 \cdot \frac{\text{gm}}{\text{m}^3} \quad \text{Y}_{\text{n}} = 0.12 \quad \text{BOD}_{\text{eff}} \coloneqq 20 \frac{\text{mg}}{\text{L}} \quad \text{SRT}_{\text{AS}} \coloneqq 7 \text{day} \\ & \text{Biomass} \\ & P_{\text{x}\_bio} \coloneqq P_{\text{X}\_het} + P_{\text{X}\_ntrf} = 1.984 \times 10^5 \frac{\text{gm}}{\text{day}} \\ & P_{\text{used\_vol}} \coloneqq \frac{P_{\text{used\_bio}}}{\text{Oday\_avg}} = 0.958 \cdot \frac{\text{gm}}{\text{m}^3} \\ & 3.20 \text{ Effluent soluble P} \qquad P_{\text{eff}} \coloneqq 14.4 \cdot \frac{\text{gm}}{\text{m}^3} - (P_{\text{rem}} + P_{\text{used\_vol}}) = 6.865 \cdot \frac{\text{gm}}{\text{m}^3} \\ & 3.21 \text{ Total phosphorus in sludge} \qquad P_{\text{sludge}} \coloneqq P_{\text{sludge}} = 0.128 \cdot \frac{9.3407 \cdot \frac{\text{kg}}{\text{day\_avg}} = 0.958 \cdot \frac{\text{gm}}{\text{m}^3} \\ & 3.22 \text{ Frithent soluble P} \qquad P_{\text{eff}} \coloneqq 14.4 \cdot \frac{\text{gm}}{\text{m}^3} - (P_{\text{rem}} + P_{\text{used\_vol}}) = 6.865 \cdot \frac{\text{gm}}{\text{m}^3} \\ & 3.21 \text{ Total phosphorus in sludge} \qquad P_{\text{sludge}} = 0.128 \cdot \frac{9.3407 \cdot \frac{\text{kg}}{\text{day\_avg}} = 0.958 \cdot \frac{\text{gm}}{\text{m}^3} \\ & 3.22 \text{ Premoval by chemical precipitation using Alum} \ Liquid Alum AL2(s04)3^* 18H2O with a 5$$

Determining the amount of alum required per day to reduce P concentration of 6.8 mg/L to 2 mg/L. Based on

literature (Metcalf 2003) 1.5 mol of Al will be needed per mole of P.  
Alum per kg of P: 
$$Alum_{kg_P} := Ratio_{Al_P} \cdot \frac{1.5}{W_{alum \ L}} = 26.901 \cdot \frac{L}{kg}$$
  
Alum required per day  $Alum_{day} := Q_{day_avg} \cdot (6.8 - 2) \frac{mg}{L} \cdot Alum_{kg_P} = 401.143 \cdot \frac{L}{day}$ 

## **Secondary clarifier**

## 3.22 Return sludge recycle ratio

$$X_{r} := 8000 \frac{gm}{m^{3}} \qquad X_{sludge} := 3000 \frac{gm}{m^{3}} \qquad Rec_{sludge} := \frac{\Lambda sludge}{X_{r} - X_{sludge}} = 0.6$$

## 3.23 Secondary clarifier area.

Application rate range 16-28 m3/m2\*d. Assuming loading as:

Application rate range 16-28 m3/m2\*d. Assuming loading as:  

$$Load_{SC} := 22 \cdot \frac{m^3}{m^2 day} \qquad A_{SC} := \frac{Q_{day\_avg}}{Load_{SC}} = 141.21 \text{ m}^2 \qquad Dia_{SC} := \left(\frac{\frac{A_{SC}}{2}}{\pi}\right)^{0.5} = 4.741 \text{ m} \qquad \begin{array}{c} \text{Two tanks} \\ \text{of } 4.8m \\ \text{diameter} \end{array}$$

v

## 3.24 Secondary clarifier solid loading.

$$SLoad_{SC} := \frac{\left(1 + \text{Rec}_{sludge}\right) \cdot Q_{day\_avg} \cdot \text{MLSS}_{aer\_conc}}{A_{SC}} = 4.4 \cdot \frac{\text{kg}}{\text{m}^2 \cdot \text{hr}} \qquad (\text{in suitable range})$$

**<u>3.25 Secondary clarification tank BOD and TSS removal.</u> Similarly to primary sedimentation tanks, a SRT of 2h is chosen. Given a non standard temperature the SRT for calculatio nhas been adjusted.** 

Retention time equivalent to 20C:

$$T_{avg} := 15.72$$
  $M_{ST} := 1.82 \cdot e^{-0.03T_{avg}} = 1.136$   $\theta_{SC_{T20_{eq}}} := \frac{\theta_{ST}}{M_{ST}} = 1.761 \cdot hr$ 

BOD removal rate:

D removal rate:  

$$a_{\text{ST}BOD} \coloneqq 0.018 \text{ hr}$$
  $b_{\text{ST}BOD} \coloneqq 0.02$   $BOD_{\text{SC}rem} \coloneqq \frac{\overset{\theta}{\text{st}BOD^{+b}\text{st}BOD^{-\theta}\text{st}T20\_eq}}{100} = 33.089 \cdot \%$ 

$$BOD_{aer_e} = 56.987 \cdot \frac{mg}{L}$$

BOD effluent from tank.

TSS removal  
rate:  

$$a_{ST_TSS} \coloneqq 0.0075 \cdot hr$$
  $b_{ST_TSS} \coloneqq 0.014$   $TSS_{SC_rem} \coloneqq \frac{\frac{\theta_{ST_T20\_avg}}{a_{ST_TSS}+b_{ST_TSS}\cdot\theta_{SC_T20\_eq}}}{100} = 54.768 \cdot \%$   
 $TSS_{aer\_e} = 45.603 \cdot \frac{gm}{m^3}$   $TSS_{SC\_eff} \coloneqq TSS_{SC\_rem} \cdot TSS_{aer\_e} = 24.976 \cdot \frac{mg}{L}$ 

Estimated total suspended solids accumulated for each

day:  $TSS_{SC\_acc} := (TSS_{aer\_e} - TSS_{SC\_eff}) \cdot Q_{day\_avg} = 64.08 \cdot \frac{kg}{day}$ 

## 4. Tertiary treatment

## Disinfection.

The technology chosen for the final disinfection is UV light. This solution provides excellent disinfection and no residuals. Given the low water volume, operational costs are limited.

For coliforms 2-log removal a dose of 30-60 mJ/cm2 is recommended (Metcalf & Eddy 2003). The estimated coliforms at this stage of the treatment is 7.7 104 MPN/100ml (Table 4). A closed vessel UV disinfection unit is proposed. Considering hourly flow is 129 m^3/hr, an inner diameter is estimated at 300 mm based on existing products. (Evoqua 2017). An inactivation constant of 0.675 cm2/mJ was used (Ye et al. 2007). A few observations can be made at possible factors that can affect the disinfection: TSS concentration is low, the pH is neutral and this will prevent scaling. Stormwater and industrial discharge, by initial assumption, are not present in the waterflow. It can be assumed that the effluent coliform concentration will be reduced to 1.2 10<sup>-5</sup> MPN/100 ml. Summary data are shown in Table 13.

## Micropollutants.

Micropollutants are new set of contaminants that has been recognized worth of attention (Deblonde, Cossu-leguille, and Hartemann 2015). This has been recognized at legislative level by the EU water framework directive 2000/06/CE Annex X which contains a list of 33 substances worth of attention. One of the main characteristics of these pollutants is the yet unknown effects on human and environmental health but water plays a crucial role in their environmental fate and wastewater plants could have a key role in limiting their concentration. Even if mandatory guidelines are not in place it may be considered that, in the near future, removal of these substances will be required. In the proposed treatment system an additional membrane filtration unit could be added for such a purpose.

## UV disinfection calculations

<u>4.1 UV dose.</u> For 2-log removal a dose of 30-60 mJ/cm2 is recommended. A close vessel of 300mm diameter is proposed. A UV unit with 3 lamps should provide enough intensity.

$$\begin{aligned} & Q_{day\_avg} = 129.443 \cdot \frac{m^3}{hr} & A_{uv} := (0.15m)^2 \cdot \pi = 706.858 \cdot cm^2 \\ & v_{uv} := \frac{Q_{day\_avg}}{A_{uv}} = 0.509 \frac{m}{s} \quad t_{uv} := 0.05 \frac{m}{v_{uv}} = 0.098 \, s \\ & P_{lamp} := 80W & I_{uv} := 3 \cdot \frac{P_{lamp}}{A_{uv}} = 0.34 \cdot \frac{W}{cm^2} \\ & D_{uv} := I_{uv} \cdot t_{uv} = 0.033 \cdot \frac{J}{cm^2} \end{aligned}$$

Influent coliform are estimated at 7.7 10<sup>4</sup>. An inactivation constant of  $0.675 \text{ cm}^2/\text{mJ}$  is used. The effluent coliform is within legislative limits.

 $k_{uv} := 0.675 \frac{cm^2}{10^{-3}J}$   $N_0 := 7.7 \cdot 10^4$   $N_{coli} := N_0 \cdot e^{-k_{uv} \cdot t_{uv} \cdot l_{uv}} = 1.268 \times 10^{-5}$ 

#### Table 13: summary table for UV disinfection

Туре	closed vessel
UV lamp	2
Sectional diameter	300 mm
Lamp power	80 W
Dose	33 mJ/cm <sup>2</sup>
inactivation k	0.675cm <sup>2</sup> / mJ
effluent coliform	1.2 10 <sup>-5</sup> MPN/100ml

## 5. Sludge management

## Sludge characteristics and quantities (calculations 5.1).

It is assumed that the wastewater source is domestic therefore it may be assumed as well that metal pollutants and trace organics are not present in significant quantity. Pathogenic organisms are present. Coliforms are present in the influent water at 1.2 107 MPN/100ml. An estimation of helminth eggs was done based on literature (Andreoli et al. 2008:45). For primary sludge 103-104, for digested sludge 102-103 gTS. The estimated quantity of sludge from primary and secondary clarifiers is 17.8 m3/day.



## Proposed treatment (calculation 5.2 5.3 5.4).

The proposed treatment system consists of a sedimentation tank and alkaline stabilization. This solution was preferred to others for its ability to perform at lower volumes and the possibility of odour control. This last factor was weighed as very relevant considering the proximity of the township. For the thickening and dewatering phase, two centrifuges are used in sequence preceded by polymer conditioning of 5 kg/ton of sludge (calculation 5.2). This treatment should achieve a solid concentration around 25% (Andreoli 2008). Lime required for stabilization is estimated at 66 kg/day. The dosage of CaO is 30% of dry-weight. Studies (EPA et al. 2003) have shown this amount should provide an acceptable removal of pathogenic organisms. This amount will also provide a rise in pH above 12 for over 2 hours, in accordance to national guidance (DEFRA 2018). The total amount of treated sludge produced per day is estimated around 257 kg. A storage unit will be necessary before the treated sludge is sold for reuse. The suggested applications are agricultural reuse and liming agent.

Summaries of the system mass balance and treatment are shown in Figure 6 and table 14.

### Sludge from chemical removal of phosphorus.

For full removal of Phosphorus, chemical precipitation is required (treatment Unit 07). Alum will be used as the chemical agent (Calculation 3.22). The sludge produced is kept separated from the overall system for a more targeted disposal and reuse. Different possibilities are available that range from aluminium recovering to agricultural use. There are still ongoing researches regarding the possible toxicity of alum in soils so further research should be done (Dassanayake et al. 2015). A precise alum sludge management plan should be defined especially in synergy with the available system of industries and facilities in the area.

### Table 14: summary of disposal for treatment byproducts

Туре	Quantity	Solid Conc.ª	Volume	Disposal
Screening	380 L/day		380 L/day	sent to nearby disposal site
Grit	7.8 m³/day	0.06 m³/day	7.8 m³/day	sent to nearby disposal site
Primary clarifier	341 kg/day	4 %	8.5 m³/day	alkaline treatment and reuse
Secondary clarifier	323 kg/day	0.7 %	9.5 m³/day	alkaline treatment and reuse
Chemical removal of Phosphorus			400 L/day	sent to other facilities for reuse

a: based on data from (Turovskii, 2006)

## Sludge treatment calculations

5.1 Sludge quantity. An influent solid concentration for the primary and secondary clarifier is estimated at 4% and 0.7%. Overall sludge produced per day:

Volume of sludge from primary clarifier

ume of sludge from primary clarifier  

$$V_{sludge\_PC} := \frac{TSS_{ST\_acc}}{4\%} \cdot \frac{m^3}{1000 kg} = 8.533 \cdot \frac{m^3}{day}$$

$$TSS_{ST\_acc} = 341.309 \cdot \frac{kg}{day}$$

Volume of sludge from secondary clarifier

$$V_{sludge\_SC} := \frac{TSS_{SC\_acc}}{0.7\%} \cdot \frac{m^3}{1000kg} = 9.154 \cdot \frac{m^3}{day}$$

 $V_{slud\_tot} := V_{sludge\_PC} + V_{sludge\_SC} = 17.687 \cdot \frac{m^3}{day}$ Total sludge

5.2 Organic polymer conditioning. A value of 5kg per metric tonne is used (Andreoli, 2008)

Assumed density of sludge 
$$\rho_{sludge} := 720 \frac{kg}{m^3}$$
  
TS<sub>thick</sub> := V<sub>slud\_tot</sub>.6%. $\rho_{sludge} = 764.081.\frac{kg}{day}$ 

$$W_{polymer} := TS_{thick} \cdot 5 \frac{kg}{1000kg} = 3.82 \cdot \frac{kg}{day}$$
 of organic polymer

5.3 Thickening and dewatering. Two centrifuges in serie are used. A final TS concentration of 25% is expected.

$$W_{TH_DW_e} := TS_{thick} \cdot 25\% = 191.02 \cdot \frac{\kappa g}{day}$$

For cost saving reasons, centrifugues are operated only 8h a day, five days a week. A tank is added. Longest period of inactivity of the centrifuges is 64 hrs (2.4 days)

 $V_{tank\_sludge} := 2.4 \cdot day \cdot V_{slud\_tot} = 42.449 \cdot m^3$  Volume is rounded at 45 m^3.

Energy consumption is calculated using an estimate of 100 kWh/ton SS.

$$\mathsf{E}_{\mathsf{cetr\_sludge}} \coloneqq \mathsf{TS}_{\mathsf{thick}} \cdot 100 \frac{\mathsf{kW} \cdot \mathsf{hr}}{\mathsf{ton}} = 84.226 \cdot \mathsf{kW} \cdot \frac{\mathsf{hr}}{\mathsf{day}}$$

5.4 Lime stabilization. A ratio of 35% lime dosing is assumed (Andreoli, 2008).

$$W_{\text{lime}} \coloneqq W_{\text{TH}_{\text{DW}_{e}} \cdot 35\%} = 66.857 \cdot \frac{\text{kg}}{\text{day}}$$
$$W_{\text{sludge}_{\text{stab}}} \coloneqq W_{\text{lime}} + W_{\text{TH}_{\text{DW}_{e}} = 257.877} \cdot \frac{\text{kg}}{\text{day}}$$

## 6. Operational carbon footprint.

### Energy consumption and technology choice.

The impact of WWTP in global warming have been highlighted by Intergovernmental Panel on Climate Change (IPCC) due to the different greenhouse gases emitted during the treatment (IPCC 2006). This is exemplified by the fact that wastewater treatment plants have to comply to the Climate Change Act that sets target of 26% emission reduction by 2020 and 80% reduction of GHG by 2050, both based on 1990 values. This tendency is in most cases in contrast with the stringent discharge requirements that not only include COD and BOD removal but also nutrients and probably in near future micropollutants. In most circumstances these two goals lead to contrasting solutions (Atkins 2008).

The design of this treatment plant is a good example of the difficulty of solving the effluent requirement-energy nexus. Eutrophication potential was considered having a larger environmental impact than the one produced by greenhouse gas emissions. Solutions addressing the first issue were given priority. Without the need for nutrients removal, a more energy efficient technology, as trickling filters, could have been chosen. The proposed technology (AAO), because of the aeration required, it is not amongst the most energy efficient but better performing than other nutrient removal systems (Table 8-17 Metcalf & Eddy 2003). Attention to reduction of energy requirement was used in the choice of other units of the treatment plant. The use of an equalization basin able to absorb daily peak flows brings a lot of advantages along the process by avoiding a design based on peak flows. This causes a reduction in volumes and loading rates. Both primary and secondary clarifiers use sedimentation as main process. In both case the design allows for low surface loading and therefore a better removal. Electrolytes are used before thickening and dewatering by centrifuges to reduce the amount of power needed. Centrifuges were preferred to a more energy efficient sedimentation tank for two reasons: limited sludge amount to be treated and the high solid concentration required by an alkaline stabilization. In addition, a sludge tank before this phase allows the centrifuges to be used only for 40 hrs a week. No thermal process is used in the stabilization of the sludge and this avoids increasing the energy intensity.

### **Operational carbon footprint.**

Several definitions exist for carbon footprint. In this study it is referred as "the total amount of direct and indirect green house gases (GHG) caused by the WWTP within the defined system boundary" (Gustavsson and Tumlin 2013). The direct and indirect emissions for this plant are summarize in Table 16. Direct emissions of CH4 and N2O will be caused by the different treatment phases. The main source for CH4 will be the oxic sub-unit with some minor emission during sludge treatment. Based on literature a range of values could be estimated between 0.25-0.7% CH4/ COD (Gustavsson and Tumlin 2013). Nitrous oxide emissions will mainly be produced by the nitrogen removal process. An estimate based on previous research could be set around a value of 1% of N2O per amount of denitrified nitrogen. Regarding indirect emissions, there have been numerous studies trying to quantify energy consumption for WWTPs. The main source is the electrical requirement to run the treatment plant. From literature a breakdown of energy demand for treatment can be down as follows: 10% pumping, 55% from treatment and 35% for sludge treatment (ESMAP 2012). Other sources will consist in the carbon footprint embedded with chemical products used and transport.

Even if a precise value for energy consumption could be given only using detailed mathematical modelling coupled with actual measurements, a few references were found in published literature that could help define a reasonable range of values. Table 15 shows four values from different studies and countries. The estimates were obtained both from software modelling (AAO, China) or measurements from actual plants. The range of values obtained is not too dissimilar ranging from 0.35 to 0.52 kW/m3 of wastewater treated.

## Table 15: energy intensity for different WWTP

Туре	kW/m³
AAO, China <sup>1</sup>	0.35
Nutrient removal, USA <sup>2</sup>	0.52
Typical plant, Germany <sup>3</sup>	0.43
Nutrient removal, Spain <sup>4</sup>	0.48
<sup>E</sup> stimated value for this study	0.4

Sources:

1 Estimate made using Biowin modelling (Wang et al. 2016)

2 Estimate based on 4 real plants

3 Average from 5668 plants (Tang 2014 cited in Wang et al. 2016)

3 Average of 3 WWTP estimates (Molinos-

Senante et al. 2011)

### Future consumption.

Considering the legislative framework previously mentioned it is not unlikely to imagine that in the future energy efficiency requirements will need to increase. A first set of optimization techniques could be implemented and are shown in Table 17. Mostly these measures are related to optimization processes and good maintenance. Other possible measures that could be implemented include anaerobic process and energy recovery from wastewater. Anaerobic digestion could be implemented as a sludge treatment process. Given the limited volume of the wastewater it would probably need to be processed together with other organic waste. This could be also done by sending the sludge no a nearby anaerobic facility. Wastewater anaerobic treatment processes in temperate climate are being studied (Lema and Suarez 2017) and it may be possible in the future to reach practical applications.

Energy recovery is another active field of research. Technologies such as microbial fuel cells, once fully developed, could help harvesting at least some of the chemical energy present in wastewater. An interesting aspect of this technology is the possibility of retrofitting existing plant.

#### Table 16: direct and indirect emissions for the wastewater plant

Direct emissions				
Unit	Emission source	Reference value	Source	
CH4	Primary sedimentation Sludge tank Sludge thickening and dewatering Discharge of wastewater	0.25%-0.7% CH <sub>4</sub> /COD influent	(Gustavsson & S. Tumlin)	
N20	AAO sludge tank discharge of wastewater	1% of the denitrified nitrogen	(Gustavsson & S. Tumlin)	
Indirect emission				
Unit	Emission source	Factor	Source	
	Electricity	0.28 kgCO2e/kWh	(BEIS 2018)	
CO <sub>2</sub> equivalent	Transport Reagents (Alum,Organic polymers, Lime)	various various	(BEIS 2018)	

#### Table 17: measures to reduce energy consumption

Unit	Description	Energy share	Possible saving (% change from total)
Pumping		10%	
	Optimization via duty software and variable speed control		-1%
	Good maintenance of plumbing fix- tures and pump casing and impeller		-3%
Treatment		55%	
	Aeration optmization using system controls, last generation diffusers		-16%
Sludge	centrifuges	35%	
Total		100%	-20%

## 7. Operational costing

During the preparation of this report it was not possible to find publicly available costing functions for the water sector in England. This could be accepted as a possibility considering the privatization of the water sector private. An estimate was done based on studies that have been carried in Spain. It was assumed that companies in the two settings run on a similar management set up. Energy costs and personnel were adjusted to UK standards using available datasets.

## **Operational expenditure (OPEX) (calculation 7.1).**

An estimated was made using a costing function developed by Hernandez-Sancho (Hernandez-Sancho, Molinos-Senante, and Sala-Garrido 2011). The equation is tailored for WWTP that include nutrient removal and based on several variables: COD, nitrogen and phosphorus reduction and years of operation.

Cost breakdown into energy, staff, reagents, maintenance and waste was based on previous studies (Hernández-Sancho, Molinos-Senante, and Sala-Garrido 2010). Energy and staff costing were adjusted to UK values using published datasets (EUROSTAT 2008) and (EUROSTAT 2005). It may be observed that one of the main variables to affect this estimate is the British Pound to Euro exchange rate. In the calculation a rate of 1.14 is used but it should be noticed that in the past 10 years exchange rate fluctuated significantly reaching value as high as 1.47 (2007, 2015) and as low as 1.05 (2008). Despite these issues a conversion of the cost was possible.

The overall OPEX were estimated at 232,200 £/year. The cost per m<sup>3</sup> of treated water is estimated at 0.205 £/m<sup>3</sup> (0.233 €/m<sup>3</sup>) which is aligned with other estimates (0.2149 €/m<sup>3</sup>) found in literature (Molinos-senante, Hernández-sancho, and Salagarrido 2010). Energy cost are estimated at 46,430 £/year which is coherent with the estimate of 43,610 £/year calculated using an energy consuption of 0.4 kW/m3 (Table 14) (Calculation 7.2). Staff costs were estimated at 85,900 £/year which may cover 3 full time technicians. Reagents costs are estimated at 34,820 £/year. Waste disposal is estimated at 27,860 £/year which is aligned with estimate (23,360 £/ year) made using a cost or 249£ per ton of dry solid (OFWAT 2015). Maintenance costs reach 37,140 £/year. This value may be lower in the first years and should allow enough budget for running the plant efficiently.

Lastly, a comparison with the data of 22 WWTPs analysed in a previous study (Molinos-senante et al. 2010) is shown in figure 8. It may be observed that the current estimate for Newtown is slightly below the average value but within a reasonable range.

## **Operation costing calculation**

## 7.1 Costing function.

Yearly volume of treated water	$V_{yr} := 3.107 \cdot 10^3 \cdot 365 = 1.134 \times 1(\frac{m3}{voor})$	
COD reduction (estimate)	COD <sub>0</sub> := 80%	
Nitrogen reduction	N <sub>0</sub> := 75%	
Phosphorus	P <sub>0</sub> := 93%	
Years	a := 1	
$C_{opex\_eu} \coloneqq 2.518 \cdot V_{yr}^{0.7153} \cdot e^{\left(0.007 \cdot a + 1.455 \cdot COD_0 + 0.258 \cdot N_0 + 0.243 \cdot P_0\right)} = 2.647 \times 10^4 \frac{euro}{year}$		
$C_{opex} := \frac{C_{opex\_eu}}{1.14} = 2.322 \times$	$10^5 \frac{\pounds}{\text{year}}$ $C_{m3} \coloneqq \frac{C_{\text{opex}}}{V_{\text{vr}}} = 0.205 \frac{\pounds}{m3}$	







Figure 8: comparison of operational costs between Newtown WWTP and 22 WWTPs in Spain.

Disaggregated yearly costs was calculated using cost breakdown based on a survey (Hernandez-Sancho et al. 2010). Values were slighly changed. Original values in brackets Values in £/year

Energy := 20%	$C_{energy} := C_{opex} \cdot Energy = 4.643 \times 10^4$
Staff := 37%	$C_{staff} := C_{opex} \cdot Staff = 8.59 \times 10^4$
Reagents := 15%	$C_{reagents} := C_{opex} \cdot Reagents = 3.482 \times 10^4$
Waste := 12%	$C_{waste} := C_{opex} \cdot Waste = 2.786 \times 10^4$
Maintenance := 16%	$C_{maint} := C_{opex} \cdot Maintenance = 3.714 \times 10^4$

Cost adjustment. Energy and staff costing is adjusted to UK standards using EUROSTAT datasets. Energy adjustment factor calculated as the percentage difference between Spain and UK average costs for industry (EUROSTAT 2008).

$$F_{energy} := \frac{11.44}{9.87} = 1.159$$

Personnel adjustment factor calculated as the percentage different between Spain and UK average personnel cost in the water sector (EUROSTAT 2005).

$$F_{\text{staff}} \coloneqq \frac{39.6}{35.4} = 1.119$$

Adjusted costs can be calculated for energy and staff

$$C_{energy\_uk} := C_{energy} \cdot F_{energy} = 5.382 \times 10^4$$
  
 $C_{staff\_uk} := C_{staff} \cdot F_{staff} = 9.609 \times 10^4$ 

7.2 Reference values. A GBP/Euro rate of 1.14 was used.

Energy

$$E_{hr} := 0.4 \frac{kW \cdot hr}{m^3} \cdot 129 \frac{m^3}{hr} = 51.6 \cdot kW$$
$$E_{yr} := E_{hr} \cdot 365 \cdot 24 = 4.52 \times 10^5 \cdot kW$$

$$C_{energy\_ref} := E_{yr} \cdot \frac{0.11}{kW} = 4.972 \times 10^4$$

Yearly electricity cost 49720 euro or 43610 £

Waste cost. Based on reported data (OFWAT 2015) a disposal cost for ton of dry solid of 249£ is used. Daily production was previously estimated at 257 kg/day.

3

$$C_{waste\_ref} := 257 \frac{kg}{day} \cdot \frac{249}{10^{3} kg} \cdot 365 \cdot day = 2.336 \times 10^{4} \frac{\pounds}{year}$$

## 8. References

Andreoli, CV, L. Garbossa, G. Lupatini, and E. Pegorini. 2008. "Wastewater Sludge Management: A Brazilian Approach." Sanare - Revista Técnica Da Sanepar 13:117–30.

ASCE. 1998. Design of Municipal Wastewater Treatment Plants. ASCE.

Atkins. 2008. Carbon Costing – Carbon Calculator Tool. Report for Southern Water.

BEIS. 2018. "Electricity Conversion Factor UK." Retrieved (https://www.gov.uk/government/publications/green-house-gas-reporting-conversion-factors-2018).

Dassanayake, K. B., G. Y. Jayasinghe, A. Surapaneni, and C. Hetherington. 2015. "A Review on Alum Sludge Reuse with Special Reference to Agricultural Applications and Future Challenges." Waste Management 38:321–35.

Deblonde, Tiphanie, Carole Cossu-leguille, and Philippe Hartemann. 2015. "Emerging Pollutants in Wastewater : A Review of the Literature." International Journal of Hygiene and Environmental Health 214(6):442–48.

DEFRA. 2018. Sewage Sludge in Agriculture: Code of Practice.

Department for Business Energy and Industrial Strategy. 2018. "Government Emission Conversion Factors for Greenhouse Gas Company Reporting." Retrieved (https://www.gov.uk/government/collections/government-conversion-factors-for-company-reporting#conversion-factors-2018).

EPA. 1987. Design Manual Phosphorous Removal.

EPA, Office of Research and Development, National Risk Management Research Laboratory, and Center for Environmental Research Information. 2003. "Control of Pathogens and Vector Attraction in Sewage Sludge Control of Pathogens and Vector Attraction in Sewage Sludge." U. S. Environmental Protection Agency 47(7):498–504.

ESMAP. 2012. A Primer on Energy Efficiency for Municipal Water and Wastewater Utilities.

EUROSTAT. 2008. "Europe in Figures - Eurostat Yearbook 2008: Energy."

Evoqua. 2017. "BARRIER<sup>®</sup> M UV SYSTEMS." Retrieved February 21, 2019 (https://www.evoqua.com/en/brands/ Wallace\_and\_Tiernan/productinformationlibrary/WT.090.370.000.DE.PS.Barrier M.pdf).

Georges, Karyn, Arthur Thornton, and Rob Sadler. 2009. Evidence: Transforming Wastewater Treatment to Reduce Carbon Emissions.

Great Lakes–Upper Mississippi River Board of State and Provincial Public. 1996. Revision 5 (Draft Edition). Recommended (Ten States) Standards for Wastewater Facilities: Policies for the Design, Review, and Approval of Plans and Specifications for Wastewater Collection and Treatment Facilities.

Gustavsson, D. J. I. and S. Tumlin. 2013. "Carbon Footprints of Scandinavian Wastewater Treatment Plants." 887–94.

Hernandez-Sancho, F., M. Molinos-Senante, and R. Sala-Garrido. 2011. "Cost Modelling for Wastewater Treatment Processes." Desalination 268(1–3):1–5.

Hernández-Sancho, Francesc, María Molinos-Senante, and Ramón Sala-Garrido. 2010. "Economic Valuation of Environmental Benefits from Wastewater Treatment Processes: An Empirical Approach for Spain." Science of the Total Environment 408(4):953–57.

IPCC. 2006. Wastewater Treatment and Discharge. In: 2006 IPCC Guidelines for National Greenhouse Gas Inventories, Vol. 5, Waste. Lema, Juan and Sonia Suarez. 2017. "Innovative Wastewater Treatment & Resource Recovery Technologies: Impacts on Energy, Economy and Environment." Water Intelligence Online 16:9781780407876.

Lin, Shun Dar. 2007. Water and Wastewater Calculations Manual. McGraw-Hill.

Metcalf & Eddy. 2003. Wastewater Engineering: Treatment and Resource Recovery. 5th Edition. edited by N. Y. McGraw-Hill.

Molinos-Senante, M., M. T. Moreira, G. Rodriguez-Garcia, G. Feijoo, A. Hospido, and F. Hernández-Sancho. 2011. "Environmental and Economic Profile of Six Typologies of Wastewater Treatment Plants." Water Research 45(18):5997–6010.

Molinos-senante, María, Francesc Hernández-sancho, and Ramón Sala-garrido. 2010. "Economic Feasibility Study for Wastewater Treatment: A Cost–benefit Analysis." Science of the Total Environment, The 408(20):4396–4402.

Moroney, J. and M. Haeck. 2004. "Aeration Control. Presentation at 'Energy Management' Conference, SWIG."

Ofwat. 2015. "Companies' Performance 2014-15." Retrieved (https://www.ofwat.gov.uk/regulated-companies/ company-obligations/performance/companies-performance-2014-15/).

OFWAT. 2015. "Appendix 1 : Sludge Treatment, Transport and Disposal – Supporting Evidence and Design Options Water 2020 : Regulatory Framework for Wholesale Markets and the 2019 Price Review." (December 2015).

Turovskiĭ, I. S. 2006. Wastewater Sludge Processing. Hoboken, N. J.: John Wiley & Sons.

UKWIR. 2005. Workbook for Quantifying Greenhouse Gas Emissions 05/CL01/3.

Wang, Hongtao, Yi Yang, Arturo A. Keller, Xiang Li, Shijin Feng, Ya-nan Dong, and Fengting Li. 2016. "Comparative Analysis of Energy Intensity and Carbon Emissions in Wastewater Treatment in USA, Germany, China and South Africa No External Power." Applied Energy 184:873–81.

Water Environmental Federation. 1995. Odor Control for Wastewater Facilities. Manual of Practice 22.

WERF. 2010. Energy Efficiency in the Water Industry: A Compendium of Best Practices and Case Studies.

Ye, Z., T. Koutchma, B. Parisi, J. Larkin, and L. J. Forney. 2007. "Ultraviolet Inactivation Kinetics of Escherichia Coli and Yersinia Pseudotuberculosis in Annular Reactors." Journal of Food Science 72(5):E271–78.